Master Planning Committee of University of Alaska Fairbanks

| Date: | April 10, 2014 | | |
|-------|---|----------|------|
| To: | Brian Rogers, Chancellor | | |
| | | Approved | Date |
| From: | Joshua Greenberg, Chair | | |
| Re: | MPC Recommendation 2014-1—Emergency generator State Lab | | |

The UAF Master Planning Committee recommends approval of the placement of an enclosed 400kw emergency generator for the State Virology Lab to be externally mounted north of the trash dumpsters, east of BiRD/Virology and West of Troth Yeddha.

Made by: Jim Dixon

Seconded by: Jonathan Shambare

Passed: Unanimous