

## PART I - GENERAL

- 1.01 Surface preparation, furnishing and installation of resilient tile (vinyl composition) or resilient sheet vinyl or linoleum floor covering and accessories on interior floor surfaces.
- 1.02 In labs, sheet goods are to be integrally coved to the room walls, thus creating the bathtub effect.
- 1.03 Rubber flooring is not preferred in labs, bathrooms, and other areas with incompatible chemicals and uses.
- 1.04 Sports and Recreation area flooring will be decided on a project by project basis by UAF FS/DDC

## PART 2 - PRODUCTS

- 2.01 Vinyl composition resilient floor tile: Design industry designation per project requirements.
  - A. Class: Per project requirements.
  - B. Wearing surface: Smooth.
  - C. Thickness: 1/8 inch.
  - D. Size: 12 inchx12 inch unless special approval by FS/DDC Project Manager.
  - E. Pattern: Similar to Armstrong Standard Excelon.
- 2.02 Resilient edge strips: Minimum 1/8 inch thick and 1 inch wide, homogenous vinyl or rubber composition, tapered or bullnose edge, color to match flooring, or from standard colors.
- 2.03 Tactile warning strips as required, minimum 1/4 inch nominal with raised profile surface pattern, manufacturer's standard heavy duty model.
- 2.04 Resilient sheet vinyl: Commercial grade products, minimum 1/8 inch thick, minimum 12 foot rolls, heat welded seams.
- 2.05 Sheet Linoleum: Commercial grade products, minimum 2.5 millimeter thick, minimum 20 inch x 20 inch tiles or 2 meter wide rolls, welded seams.
- 2.06 Rubber Sheet Flooring: Commercial grade products, minimum 3 millimeter thick vulcanized, welded seams, tiles or rolls. Ensure compatibility with room use prior to specifying.

- 2.07 Rubber wall base: Manufacturer's standard, rubber of size and profile designed per project requirements and manufacturer's standard color selection.
- A. General use areas 4-inch height.
  - B. At toilets, food service, and wet areas, 6 inch height.
  - C. 1/8-inch gage thickness.
  - D. Standard top-set cove or carpet style.
  - E. Matte finish.
  - F. Field formed base inside and outside corners with long legs.

PART 3 – EXECUTION (NOT USED)

END OF SECTION