

### **APPENDIX C: ROOF ACCESS AND RESTRICTIONS**

Roofs are restricted to Authorized personnel due to inherent dangers. Some UAF Facility roofs lack adequate fall protection devices while others have numerous lab/fumehood exhaust stacks. Exhaust air from labs is known to be contaminated with various chemicals, and biological and radioactive matter. All UAF facilities require written permission from the UAF Facilities Service Safety Officer.