



Douglas Schrage, Fire Chief
907-474-5770
907-474-5999 fax
drschrage@alaska.edu
www.uaf.edu/fire

P.O. Box 755540, Fairbanks, Alaska 99775-7540

FIRE AND LIFE SAFETY PLAN REVIEW SUBMITTAL REQUIREMENTS – FIRE SUPPRESSION SYSTEMS

Please submit the following items together, coordinated with the UAF Fire Marshal, and turned in at the same time. Complete submittals expedite processing and review time until permits are approved.

PROJECT / SUBMITTAL DOCUMENTS ARE NOT ACCEPTED ON PAPER UNLESS PRE-APPROVED BY THE FIRE MARSHAL

SUBMIT: 1 Electronic copy on disk, thumb drive, or other appropriately arranged means in Portable Document Format (.PDF) of the following:

- [] 1) APPLICATION FOR FIRE AND LIFE SAFETY PLAN REVIEW; complete with signature
- [] 2) TITLE SHEET; includes: project/building name, complete address **OR** GPS decimal coordinates of a measured point on building (use established address or coordinates for building)
- [] 3) WRITTEN NARRATIVE; provide design intent and system description
- [] 4) WORKING PLANS; Coordinate submittals directly with Fire Marshal, but plans need to conform to the current applicable editions of:
 - a. Carbon dioxide fire-extinguishing systems – NFPA 12
 - b. Halon 1301 fire extinguishing systems – NFPA 12A
 - c. Dry-chemical extinguishing systems – NFPA 17
 - d. Wet-chemical extinguishing systems – NFPA 17A
 - e. Water-mist systems – NFPA 750
 - f. Clean-agent extinguishing systems – NFPA 2001
 - g. Aerosol fire-extinguishing systems – NFPA 2010
 - h. Other – as determined with Fire Marshal upon consult.
- [] 5) DEVICE SPECIFICATION AND DETAILS (i.e. cutsheets); includes for all devices used as part of the system.

ABOVE LIST IS NOT COMPREHENSIVE - ADDITIONAL INFORMATION MAY BE REQUESTED AS NEEDED TO DETERMINE COMPLIANCE WITH ADOPTED CODES AND STANDARDS